



SOUTHERN PLATTE FIRE PROTECTION DISTRICT

8795 NW N HWY., KANSAS CITY, MISSOURI 64153 • (816) 741-2900
FAX: (816) 741-7292

CLASS C RESALE (TENT) FIREWORKS APPLICATION

Date Permit Number

Applicant Information

Applicant's Name
Applicant's Business Name
Applicant's Address
Applicant's Phone Emergency Phone

Stand Location
Emergency Contact at Stand
Emergency Phone for Stand
Number of People sleeping overnight in stand
Size of Tent Is Tent Flame Resistant ?

Insurance Information

Insurance Amount \$ (Minimum required by code - \$1,000,000.00)
Insurance Company Name
Insurance Agent or Broker
(Southern Platte Fire Protection District must be listed as additionally insured)

Code Requirements: See attached sheet

Site Inspection

Date Pass Fail Inspector
30 ft. clearance to combustible grass and debris
30 ft. clearance from vehicle parking to tent
Signs stating No Fireworks Discharged within 100 feet of Tent (4" letters)
Fireworks - No Smoking (within 25 ft.)
No trailers within 30 ft. of tent
Fire extinguishers every 35 ft. (minimum one water extinguisher)
Tent sidewalls 75 ft. to any structure
Portable generators minimum of 20 ft. to tent
Exit travel distance 35 ft. - (75 ft. from the most remote point to exit)
Aisles minimum width - 48"
Exit openings to outside - 44"
Extension cords protected and minimum of 14 gauge

Falsification of information will cause denial of application

06/06